

**\*\*THIS IS NOT AN ALL INCLUSIVE LIST\*\***

**Certificate of Compliance:** Permit Application and fee of \$200.00 includes one inspection. If the inspection does not pass you will receive a report listing items needing corrections. There is a \$250.00 re-inspection fee that must be paid prior to re-scheduling.

Must have active power to complete the inspection

Fire access roads need to allow access to building

Fire lane markings shall include the words NO PARKING/FIRE LANE striping or signs; refer to the fire code @ [www.fbcfmo.org](http://www.fbcfmo.org) bottom of the home page

Address Identification must be plainly visible to public; letters and numbers shall contrast with the background; refer to the fire code @ [www.fbcfmo.org](http://www.fbcfmo.org) bottom of the home page

Suite number or letter posted above front door

Electric panels maintain 36 inches clearance and nothing in front

Junction boxes verify for no missing knock outs in electrical boxes above and below ceiling

No open junction boxes above and below ceiling

No open or exposed wiring; extension cords cannot be used as the permanent source

Extinguisher requirement; hung on brackets with top no higher than 5ft off the ground; must be 75 feet travel distance and mounted in exit pathways; post signage indicating location

Minimum 5lb ABC Extinguishers and must be tagged by licensed technician annually and after each use

Locks and latches on operating doors; ***This door to remain unlocked when building is occupied*** (bottom inside of door)

Exit signs shall be illuminated and tested for emergency power back-up

Emergency lighting /egress lighting inside and outside

Remove any obstruction from exits, aisles, fire escapes; keep storage areas orderly

Mechanical room cannot be used for storage

Ceiling clearance must be 18 inches away from ceiling if sprinkled

Ceiling clearance must be 24 inches away from ceiling if not sprinkled

Existing Hood systems must be tagged/good

Existing Fire Alarm must be tagged/good

Existing Fire Sprinkler must be tagged/good

**\*\*THIS IS NOT AN ALL INCLUSIVE LIST\*\***