




Williamson County Emergency Services District No.5

Fire Lane Detail

NOTES:

FIRE LANE STRIPING TO BE 6" WIDE RED PAINT WITH "FIRE LANE TOW AWAY ZONE" IN 4" TALL WHITE LETTERS. WORDING MAY NOT BE SPACED GREATER THAN 30' APART. STRIPING TO BE PAINTED ON THE FACE OF CURB WHEN PRESENT AND PAINTED FLAT ON THE PARKING SURFACE WHEN IT IS NOT.



FIRE LANE STRIPING DETAIL

not to scale

Updated 02/11/2026

D:\Standards\Const-Stnds\Fire-Lane-Striping_Curb.dwg

Jay Engineering Company, Inc. P.O. Box 1220 Leander, Texas 78646-1220 Tel. (512) 259-3882 Fax. (512) 259-8016 TEXAS REGISTERED ENGINEERING FIRM F-4780	FIRE LANE STRIPING DETAIL			
	ENGINEER	DATE	DRAWN BY	PROJECT NO.
FRANK T. PHELAN, P.E.	04 - 25 - 19	JJD	01	1 OF 1