


NOTES:


FIRE LANE STRIPING TO BE 6" WIDE RED PAINT WITH "FIRE LANE TOW AWAY ZONE" IN 4" TALL WHITE LETTERS. WORDING MAY NOT BE SPACED GREATER THAN 30' APART. STRIPING TO BE PAINTED ON THE FACE OF CURB WHEN PRESENT AND PAINTED FLAT ON THE PARKING SURFACE WHEN IT IS NOT.



**FIRE LANE STRIPING DETAIL**

not to scale

D:\Standards\Const-Stnds\Fire-Lane-Striping\_Curb.dwg

 Jay Engineering Company, Inc. P.O. Box 1220 Leander, Texas 78646-1220 Tel. (512) 259-3882 Fax. (512) 259-8016 TEXAS REGISTERED ENGINEERING FIRM F-4780	<b>FIRE LANE STRIPING DETAIL</b>			
	ENGINEER	DATE	DRAWN BY	PROJECT NO.
FRANK T. PHELAN, P.E.	04 - 25 - 19	JJD	01	1 OF 1